

## Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H

Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

www.heber.ca.gov

January 4, 2024

Attention: Madeline Dessert  
General Manager

SUBJECT: Heber W.W.T.P. Operations from November 21, 2023 through December 21, 2023.

- A. Major violations: (NONE)
- B. Minor violations: (NONE)
- C. Major sewer spills: (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning. Changed bulbs, sleeves, and wiper canisters on Bank 2B lamp set number 4.
- F. Vector Truck: No use of the vector truck this monthly cycle.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 0.
- H. From November 21, 2023 through December 21, 2023: Heber Wastewater Plant received and treated 14,691 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of December 21, 2023.

Sincerely,

A handwritten signature in blue ink, appearing to be "E. Gonzalez".

Edoardo S. Gonzalez  
Wastewater Plant Lead Operator



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

January 5, 2024

Attention: Madeline  
General Manager

Subject: Water Distribution Report December 2023

A) Water breaks (0)

B) Service Leak (1)

1. 35 Cantaloupe Street

C) Work orders ( 39 )

HYDRT - HYDRANT LEAK-----	1
INFO - TEST METER -----	9
MC - METER CHANGE-----	3
CON - CONNECT -----	3
MISC - MISC REPORT -----	1
OCC - OCCUPANT CHANGE-----	2
DIS - DISCONNECT -----	3
LEAK - METER LEAK-----	8
FIREF - ENCODER-FIREFLY-----	6
SWR - SEWER PLUG UP-----	1
WTR - SERVICE LINE LEAK-----	1
PRSUR- TEST WATER PRESSURE-----	1

**TOTAL ALL CODES** **39**

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H  
Heber CA 92249  
Tel:(760)482-2440 • Fax (760)353-9951  
[www.heber.ca.gov](http://www.heber.ca.gov)

January 5, 2024

Attention: Mrs. Dessert  
General Manager

Subject: December 2023 Monthly Report

On the billing cycles ending on the 21st of December 20,976,000 gallons of water were used by our consumers, an average of 699,000 gallons was used per day.

On December 14, 2023, collected the monthly Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on December 26, 2023 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 66 ppb for the McCabe site and 51 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

On December 7, 2023 received a call from the Imperial County Lab informing that one of our bacteriological samples was positive for total coliform. On December 8, 2023 we retested the original site in addition to two more locations (upstream and downstream of the original site.) On December 9, 2023 the Imperial County Lab informed that the retesting results were negative, meaning the water is safe. Heber Public Utility District did not acquire any violations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District




HEBER PUBLIC UTILITY DISTRICT

Water & Wastewater Treatment Plants and Billing Report  
 Billing Period : November 21, 2023 THRU December 21, 2023

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Nov-22	21,098,000	21,818,114	2,001,747	-2,721,861	13,790,000	\$ 132,114.00	\$ 115,944.89	\$ 48,036.01	166 Accounts
Dec-22	16,718,000	18,899,726	1,152,370	-3,334,096	12,914,000	\$ 127,793.03	\$ 115,741.65	\$ 48,156.83	160 Accounts
Jan-23	14,758,000	16,955,789	1,470,536	-3,668,325	12,359,000	\$ 125,914.47	\$ 115,765.18	\$ 48,298.97	160 Accounts
Feb-23	14,866,000	17,436,262	1,819,310	-4,389,572	15,419,000	\$ 125,185.58	\$ 115,755.26	\$ 48,228.82	160 Accounts
Mar-23	14,912,000	18,525,257	1,956,134	-5,569,391	16,565,000	\$ 126,234.37	\$ 116,209.30	\$ 48,749.15	160 Accounts
Apr-23	19,578,000	23,851,240	2,467,680	-6,740,920	13,959,000	\$ 137,270.06	\$ 116,752.65	\$ 54,129.28	160 Accounts
May-23	24,937,000	27,283,599	2,091,376	-4,437,975	13,429,000	\$ 145,124.77	\$ 116,710.16	\$ 54,054.90	160 Accounts
Jun-23	28,781,000	29,925,186	2,454,108	-3,598,294	14,212,000	\$ 149,604.48	\$ 117,451.77	\$ 54,154.44	160 Accounts
Jul-23	30,540,000	33,019,108	2,481,826	-4,960,934	12,877,000	\$ 158,940.92	\$ 117,756.38	\$ 55,755.67	160 Accounts
Aug-23	31,134,000	29,923,590	2,513,664	-1,303,254	13,991,000	\$ 150,960.04	\$ 117,671.85	\$ 55,810.93	160 Accounts
Sep-23	34,405,000	27,531,530	2,616,579	4,256,891	13,723,000	\$ 143,774.19	\$ 117,357.33	\$ 55,767.32	160 Accounts
Oct-23	30,110,000	27,412,985	2,231,252	465,763	14,544,000	\$ 144,521.19	\$ 117,579.77	\$ 55,759.60	160 Accounts
Nov-23	24,697,000	23,117,991	1,764,615	-185,606	15,743,000	\$ 137,195.23	\$ 117,267.22	\$ 55,685.68	160 Accounts
<b>Dec-23</b>	<b>20,976,000</b>	<b>21,708,288</b>	<b>2,543,739</b>	<b>-3,276,027</b>	<b>14,691,000</b>	<b>\$ 135,839.85</b>	<b>\$ 116,781.70</b>	<b>\$ 55,576.30</b>	<b>160 Accounts</b>

Totals includes billing for final accounts  
 To the best of my knowledge, the information is true and correct.

  
 Liz German  
 Office Senior Clerk

11/4/2024  
 Date

## \*\*\*\* TOTALS BY JOB CODE \*\*\*\*

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
HYDRT - HYDRANT LEAK	1	0	0	0	0
LEAK - METER LEAK	8	0	0	0	0
MISC - MISC REPORT	1	1	0	0	0
PARK - PARKS	0	1	0	0	0
WTR - SERVICE LINE LEAK	1	1	0	0	0
DIS - DISCONNECT	3	0	0	0	10
INFO - TEST METER	9	1	0	0	0
MC - METER CHANGE	3	0	0	0	0
PRSUR - TEST WATER PRESSURE	1	1	0	0	0
FIREF - ENCODER/FIRELY	6	0	0	0	0
SWR - SEWER PLUG UP	1	0	0	0	0
TEMP - TEMP SHUT OF FOR REPAI	0	1	0	0	0
CON - CONNECT	3	0	0	0	0
OCC - OCCUPANT CHANGE	2	0	0	0	0
TOTAL ALL CODES	39	6	0	0	10