



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

www.heber.ca.gov

July 6, 2026

Attention: Madeline
General Manager

Subject: June 2026 Monthly Report

On the billing cycle ending on the 21st of June 34,394,000 gallons of water were used by our consumers, an average of 1,075,000 gallons was used per day.

On June 8, 2026, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on June 15, 2026 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 56 ppb for the Mc Cabe site and 45 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

July 6, 2026

Attention: Madeline
General Manager

Subject: Water Distribution Report June 2026

- a) Water breaks (2)
 - 1. 1118 Valley Blvd
 - 2. 1120 Valley Blvd
- b) Service Leak (1)
 - 1. Heber School 11th Street

c) Work orders (126)

INFO - TEST METER	1
OCC - OCUPANT CHANGE	4
CON - CONNECT	3
MISC- MISC REPORT	3
DIS - DISCONNECT	2
PRSUR - TEST WATER PRESSURE	2
LEAK - METER LEAK	10
MT PR - METER CHANGING PROJECT	95
HYDRT - HYDRANT LEAK	1
ONCAL - ONCALL OPERATOR WAS CALLED	3
BEES - BEES IN METER	1
SEWER - SEWER PLUG UP	1
 TOTAL ALL CODES	 126

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Water Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd., Suite 103 · P.O. Box H
Heber, CA 92249
TEL. (760) 482-2440 · FAX (760) 353-9951
www.heber.ca.gov

July 13, 2026,

Attention: Madeline Dessert, General Manager

Subject: Heber Public Utility District Waste Water Treatment Plant Operations from May 20, 2026 through June 20, 2026

- A. Minor Violation: (Failed Bacti sample)
- B. Major Sewer Spills: (minor sewer spill June 27th)
- C. Main Sewer Plugs: (Partial sewer obstruction June 27th)
- D. UV System: Operational; Self-Cleaning
- E. Vactor Truck: Truck was out for welding repairs on tank. Not used.
- F. From May 20, 2026 through June 20, 2026 Heber Public Utility District Waste Water Treatment Plant received and treated 11.76 MG
- G. Heber Public Utility District did not exceed the daily maximum flow (1.2 MGD) as of June 20, 2026

Sincerely,

Matthew Hughes
Lead Operator
Heber Public Utility District



HEBER PUBLIC UTILITY DISTRICT

Water & Wastewater Treatment Plants and Billing Report Billing Period : MAY 20, 2026 thru JUNE 21, 2026

	<i>Water</i>		<i>HPUD Offices/Parks</i>	<i>Difference Water</i>	<i>Sewer</i>	<i>Invoiced</i>	<i>Invoiced</i>	<i>Invoiced</i>	<i>10% Trash Senior Discount</i>
<i>Month & Year</i>	<i>Gallons Produced</i>	<i>Gallons Invoiced</i>	<i>Gallons not invoiced</i>	<i>Water not accounted</i>	<i>Influent</i>	<i>Water</i>	<i>Sewer</i>	<i>Trash</i>	<i># of Accounts receiving the discount</i>
Jun-25	33,319,000	30,156,796	3,031,154	131,050	14,599,000	\$ 148,780.49	\$ 117,216.21	\$ 59,639.17	170 Accounts
Jul-25	35,710,000	30,330,332	412,788	4,966,880	14,157,000	\$ 157,505.88	\$ 117,382.10	\$ 61,603.45	173 Accounts
Aug-25	35,291,564	37,781,000	5,036,022	-2,489,436	14,603,000	\$ 159,459.05	\$ 118,187.81	\$ 61,533.43	173 Accounts
Sep-25	31,146,000	29,481,327	4,340,771	1,664,673	14,943,000	\$ 144,984.94	\$ 121,164.92	\$ 61,518.45	173 Accounts
Oct-25	23,984,000	23,340,443	1,371,609	643,557	13,174,000	\$ 136,318.39	\$ 116,871.77	\$ 61,503.80	173 Accounts
Nov-25	22,739,000	21,469,843	1,101,047	1,269,157	13,178,000	\$ 134,331.13	\$ 117,937.44	\$ 61,617.85	173 Accounts
Dec-25	16,748,000	16,854,457	745,323	-106,457	12,762,000	\$ 126,739.03	\$ 122,950.77	\$ 63,452.48	173 Accounts
Jan-26	17,318,000	18,057,257	630,422	-739,257	13,091,000	\$ 129,272.97	\$ 123,312.57	\$ 65,095.68	173 Accounts
Feb-26	18,466,000	19,480,505	1,495,029	-1,014,505	13,272,000	\$ 130,545.76	\$ 123,800.03	\$ 65,026.29	173 Accounts
Mar-26	22,916,000	22,422,232	1,804,841	493,768	11,762,000	\$ 135,763.78	\$ 124,028.87	\$ 64,989.70	173 Accounts
Apr-26	25,437,000	26,044,541	1,747,837	-607,541	12,199,000	\$ 141,558.48	\$ 123,778.17	\$ 65,045.63	173 Accounts
May-26	31,471,000	30,936,155	1,340,825	534,845	12,148,000	\$ 161,929.44	\$ 123,753.11	\$ 64,935.82	173 Accounts
Jun-26	34,394,000	34,504,797	1,335,512	-110,797	11,760,000	\$ 169,962.97	\$ 124,679.03	\$ 65,200.06	173 Accounts

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.

Liz German

Liz German
Office Senior Clerk

07/13/2026

Date

**** TOTALS BY JOB CODE ****

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
DIS - DISCONNECT	2	0	0	0	16
MISC - MISC REPORT	3	0	0	0	0
LEAK - METER LEAK	10	0	0	0	0
MT PR - METER CHANGING PROJECT	95	7	0	0	1
CON - CONNECT	3	0	0	0	0
HYDRT - HYDRANT LEAK	1	0	0	0	0
BEES - BEES IN METER	1	0	0	0	0
ONCAL - ONCALL OPERATOR WAS CA	3	0	0	0	0
INFO - TEST METER	1	0	0	0	0
PRSUR - TEST WATER PRESSURE	2	1	0	0	0
SEWER - SEWER PLUG UP	1	0	0	0	0
OCC - OCCUPANT CHANGE	4	0	0	0	0
WTR - SERVICE LINE LEAK	0	1	0	0	0
TOTAL ALL CODES	126	9	0	0	17